



REQUEST FOR BID PROPOSALS

Fire Hydrants & Accessories

Due: Thursday, July, 24, 2025 at 10:00 AM

Village of Tannersville

PO Box 967, 1 Park Lane, Tannersville, NY 12485

VILLAGE OF TANNERSVILLE FIRE HYDRANTS AND ACCESSORIES

The Village of Tannersville is soliciting bids for the furnishing and delivery of new fire hydrants, valves, and accessories. Project includes labor, tools, materials, and delivery costs necessary to furnish the new equipment and accessories as noted below. Sealed Bids for the furnishing and delivery of the equipment and materials will be received at the Village of Tannersville Municipal Building (1 Park Lane, Tannersville, NY 12485) until **10:00 AM on Thursday July 24th, 2025** at which time the proposals received will be opened and read aloud.

I. General Requirements

1. All bids shall include all tools, labor, materials, and equipment and delivery costs necessary to furnish and deliver new and fully functional fire hydrants (Qty. = 4) and 6-inch Gate Valves and valve boxes (Qty. = 4) to the Village of Tannersville DPW Garage located at 105 Railroad Ave, Tannersville, NY 12485 between normal business hours (8AM to 3PM).
2. All bids must be made on the blank form of the proposal attached hereto. Forms that must be submitted with the Bid, and are included in Attachment A include:
 - Bid Form
 - Non-Collusive Bid Certification
3. A bidder may withdraw any bid submitted prior to the hour set for the closing of the bids provided the request is signed in a manner identical with the proposal being withdrawn.
4. Bids can be submitted via email to the Village Clerk tannersvillewater@gmail.com, or delivered to the Village rooms at the address listed previously. Use of the US Postal Service for delivering the bid is not recommended.
5. All bid questions shall be submitted in writing to Jason Preisner, PE at jpreisner@lamontengineers.com. Phone number: (518)929-7838.
6. The Village Board of the Village of Tannersville reserves the right to waive any informalities or irregularities in the bids received and to reject any or all bids without explanation.
7. If the bid is to be awarded, the Owner will award the contract to the Bidder with the lowest responsible bid for the Total Base Bid.

8. The Owner will be responsible for payment in accordance with the terms of the contract upon delivery and acceptance of the equipment.
9. The Owner is exempt from New York State sales taxes on material, supplies, and equipment. Exemption No. 14-6002465. Said taxes shall not be included in the Bid.
10. Equipment and Materials furnished and delivered to the Village to be performed as a contract with the Village of Tannersville. Payment shall be based on % of work completed or other negotiated terms.
11. All equipment, materials and accessories shall be fully delivered to the Village by **August 15, 2025** unless otherwise authorized by the Village.
12. Once under contract, Contractor shall provide submittal for materials to be furnished to Village Engineer for review and approval prior to commencing work.

II. Equipment and Materials Specifications

FIRE HYDRANTS

- A. AWWA C502-94.
- B. Main Valve Opening: 5 1/4 inches.
- C. Stem seals: Double O-ring.
- D. Depth of Trench or Bury: 5 1/2 feet.
- E. Inlet Connection:
 1. 6-inch mechanical joint.
 2. Accessories include ductile iron glands, high-strength low-alloy steel tee bolts and nuts, plain backed rubber gaskets and required joint lubricant.
- F. Nozzle Arrangement:
 1. Two 2-1/2-inch hose connections with nozzle caps and chains.
 2. One 4-1/2-inch pumper connection with nozzle cap and chain.
 3. Threads shall be National Standard Thread (NST).
- G. Operating Nut and Nozzle Cap Nuts: 1. Five-sided pentagon measuring 1-1/2 inches from point to opposite flat side.
- H. Direction of Opening: Open Left.
- I. Break Flange:
 1. All fire hydrants shall be of break flange construction with a frangible break flange located slightly above the ground line and a cast iron break coupling on the stem at the same location which shall be so designed that in case of breakage, only the break flange and cast-iron coupling need to be replaced to complete the repair.
- J. Bolts: 304 Stainless Steel
- K. Color: Red
- L. All Hydrants shall be Kennedy K-81D, Mueller Super Centurion A-423, or approved equal.

IRON-BODY GATE VALVES

- A. Valve Size: 6-inch.
- B. Standards: 1. AWWA C-509 for Resilient Wedge Gate Valves.

- C. Valves shall have an Epoxy Coating certified to meet NSF 61 Standards.
- D. Bolts: 304 Stainless Steel
- E. Stem Construction:
 - 1. All valves shall be non-rising stem (NRS).
- F. Stem Seals: O-ring.
- G. Gate Type: Resilient Wedge.
- H. End Connections: Valves will be installed underground and shall be mechanical joint type.
- I. Operators:
 - 1. Direction of rotation to open: Open Left with operator marked to show direction to open.
 - 2. Wrench nuts without extension stems: For valves installed underground.
- J. Gate valves (3"-12") shall be Resilient Wedge Gate Valves.
 - 1. Mueller Catalog No. A-2360.
 - 2. American Darling Series 2500.
 - 3. Or approved equal.
- K. Valve Boxes: Valve boxes shall be cast iron and marked "water"
 - 1. Valve boxes shall be 2 pieces, with flange top piece and bell base.

**ATTACHMENT A – BID PROPOSAL FORM
 Village of Tannersville
 Water Main Materials and Accessories**

Place: Village of Tannersville

Date: _____

1. In compliance with your invitation for bids, and subject to all the conditions thereof, the

Undersigned (hereinafter called BIDDER doing business as)

_____, a corporation

incorporated in the State of _____ a partnership /or an individual, of the

City of _____, State of _____ hereby proposes to furnish and

deliver the following:

Base Bid					
Pay Item No.	Pay Item Description	Qty.	Unit	Unit Price (\$)	Total Price (\$)
1.	Fire Hydrant Assembly & Accessories	4	EA		
2.	6" Gage Valve with Valve Box	4	EA		

Total Base Bid (Item 1 + Item 2): _____

_____ (\$ _____).

Estimated Delivery Date _____

- A. Each Pay Item price shall include an amount considered by BIDDER to cover BIDDER overhead and profit for each separately identified Pay Item.

2. The undersigned BIDDER does hereby declare and stipulate that this proposal is made in good faith, without collusion or connection with any other person or persons bidding for the same work, and that it is made in pursuance of and subject to all the terms and conditions of the Notice and Instructions to Bidders, the Contract, the Specifications, pertaining to the equipment and accessories to be provided, all of which have been examined by the undersigned.

Furthermore, BIDDER has examined the following Addenda to the Contract Documents (receipt of all which is hereby acknowledged):

Addendum No.	Date
_____	_____
_____	_____

3. BIDDER is familiar with and is satisfied as to all federal, state and local Laws and Regulations that may affect cost, progress and performance of the Work.

4. All the various phases of work enumerated in the general requirements with their individual jobs and overhead, whether specifically mentioned, included by implication or appurtenant thereto, are to be performed by the BIDDER irrespective of whether it is named in said general requirements.

5. Payment for the materials and accessories shall be as noted in general requirements.

BIDDER'S Federal I.D. No.

BIDDER

Seal (if a corporation)

By _____

Title

(Business Address)

**ATTACHMENT B:
NON-COLLUSIVE PROPOSAL CERTIFICATE
PURSUANT TO NEW YORK STATE GENERAL MUNICIPAL LAW SECTION 103-D**

By submission of this proposal, each proposer and each person signing on behalf of any proposer certifies, and in the case of a joint proposal each party thereto certifies as to its own organization, under penalty of perjury, that to the best of knowledge and belief:

1. The prices in the proposal have been arrived at independently, without collusion, consultation, communication or agreement, for the purpose of restricting competition, as to any matter relating to such prices with any other proposer or with any competitor;
2. Unless otherwise required by law, the prices which have been quoted in this proposal have not been knowingly disclosed by the proposer and will not knowingly be disclosed by the proposer prior to the opening, directly or indirectly, to any other proposer or to any competitor; and
3. No attempt has been made or will be made by the proposer to induce any other person, partnership, or corporation to submit or not to submit a bid for the purpose of restricting competition.

Date

Signature

Print Name and Title

Company Name